

RFP Addendum: Uninterruptable Power Supply (UPS)

**2/15/2016**

Section IV. Project Scope

The school district preferred devices are incorrect. Only 20 amp power receptacles are available at all locations. There are no 30 amp twist lock receptacles available. Vendors are requested to bid similar capacity devices for 20 amp power feeds.